

San Diego State University
 PSFA Building IAQ Assessment
 Coal Tar Pitch Volatiles (CTPV)
 Time Weighted Average (TWA)

EMSL Sample No.	Sample Name	Sample Location	Air Volume (L)	CTPV / Asphalt Mass (mg)	CTPV(PEL) (mg/m3)	CTPV/Asphalt Concentration (mg/m3)	CTPV/Asphalt Concentration TWA (mg/m3)
281901178-0001	PSFA-031119-01	PSFA Rm 212B	570	<0.15	0.2	<0.26	n/a
281901178-0002	PSFA-031119-02	PSFA Hallway Rm. 153	555	<0.15	0.2	<0.27	n/a
281901178-0003	PSFA-031119-03	PSFA Rm. 361	585	<0.15	0.2	<0.26	n/a
281901178-0004	PSFA-031119-04	PSFA Rm 436B	555	0.26	0.2	0.46	0.18
281901178-0005	PSFA-031119-05	PSFA Rm 102	570	0.28	0.2	0.48	0.19
Lab Blank			0	<0.15	0.2	n/a	n/a